



CHARTER TOWNSHIP OF PORT HURON

2015 Michigan Residential Energy Code

Worksheet for New Single-family Residential Building

www.PortHuronTownship.org

KLavigne@PortHuronTownship.org

Complete Form And Submit It With Your Application For A New Single-Family Residential Building Permit.

Project Address:	
-------------------------	--

Part I – Choosing a Method to Comply with the Energy Code

In addition to other mandatory requirements noted below, energy code provisions require you to choose one of four alternative compliance paths to demonstrate code compliance. Indicate the path you choose below **by checking one** of the following boxes and completing the instructions.

Prescriptive (as prescribed by the code)

If you choose to use the prescriptive method of compliance, you may demonstrate compliance by completing the attached Prescriptive Compliance Report Form. Sign the compliance statement below and attach a copy of the completed Prescriptive Compliance Report Form along with this form when submitting for a building permit. Please note that the prescriptive insulation materials and methods shown on the building plans shall match what is indicated on the compliance report.

Total UA Alternative (prescriptive trade-off method)

Compliance with the Total UA Alternative method may be demonstrated by completing a compliance report using **REScheck software provided free of charge at www.energycodes.gov/rescheck**. At present, REScheck does not offer a code edition incorporating State of Michigan amendments. However, you may use the 2015 International Energy Conservation Code (2015 IECC) since it meets or exceeds Michigan requirements. Please use "Utica, Michigan" for location criteria. Sign the compliance statement below and attach a copy of a signed compliance report, including the inspection checklist, with this form when submitting for a building permit. Please note that the building plans shall show the same materials and methods you use to complete the REScheck form. For example, if you use basement wall insulation in REScheck, such insulation should be clearly indicated on the building plans too.

Simulated Performance Alternative (performance analysis)

Certain commercially available compliance software (e.g. REM/RATE, etc.) may be used to demonstrate that the proposed construction will have an annual energy cost that is less than or equal to the energy cost of the standard reference design. Please see Section N1105 of the code for specific criteria.

Such software shall generate a compliance report that documents that the proposed design complies and shall include information outlined in Section N1105. Sign the compliance statement below and attach a copy of the completed compliance report with this form when submitting for a building permit.

Above Code Programs

Compliance with certain energy efficiency programs such as Energy Star Version 3 and ICC 700-2012 "silver" are acceptable. See Section N1101.7 and N1106 for specific provisions. Provide a compliance report that documents that the proposed design meets program requirements. **Sign the compliance statement below and attach a copy of the completed compliance report with this form when submitting for a building permit.**

Part II - Compliance Statement

I have read and completed the enclosed form and will insure that the actual construction complies with Chapter 11 of the 2015 Michigan Residential Code.

Applicant:	Signature	Date
-------------------	-----------	------

This form is intended to provide a simplified method of documenting prescriptive code compliance. Please see the full code context for exceptions, alternatives and other requirements that may apply.

Prescriptive Compliance Report Form: Note that this form is **only** required if you use the Prescriptive Compliance path. In the table below, **indicate the proposed values** of insulation, fenestration and other components. Please note that such components shall meet or exceed the performance of the prescribed values. If you have any clarifications, please note them in the comment section. Finally, insure that the building plans submitted show the same materials and methods you use to complete this form.

Component Description ^a	Prescribed Value	Proposed Value	Comment/Description
Fenestration U-Factor	0.32		
Skylight U-Factor ^b	0.55		
Ceiling R-Value	38		
Wood Frame R-Value	20 or 13+5 ^g		
Mass Wall R-Value ^h	13/17		
Floor R-Value	30 ^f		
Basement Wall R-Value ^c	10/13		
Slab R-Value/Depth ^e	10/2 feet		
Crawl Space Wall R-Value ^d	15/19		
Ducts outside building thermal envelope (i.e. attic spaces) R-Value	8		
Ducts within building but outside conditioned space (i.e. crawls spaces) R-Value	6		
Ducts within building envelope assembly, insulation placed between duct and unconditioned space R-value	8		
High-efficacy lamps in permanently installed light fixtures - Percentage	75%		
Attic access doors - Doors shall be weather-stripped and insulated to level of ceiling insulation. A wood frame or equivalent retainer is required around the access when loose fill insulation is used.			

a. R-values are minimums. U-factors are maximums.

b. The fenestration U-factor excludes skylights.

c. "10/13" means R-10 continuous insulation on the interior or exterior of the home or R-13 cavity insulation at the interior of the basement wall.

d. "15/19" means R-15 continuous insulation on the interior or exterior of the home or R-19 cavity insulation at the interior of the crawlspace wall.

"15/19" may be met with R-13 cavity insulation on the interior of the crawlspace wall plus R-5 continuous insulation on the interior or exterior of the home.

e. R-5 shall be added to the required slab edge R-values for heated slabs.

f. Or insulation sufficient to fill the framing cavity, R-19 minimum.

g. First value is cavity insulation, second is continuous insulation or insulated siding, so "13 + 5" means R-13 cavity insulation plus R-5 continuous insulation or insulated siding. If structural sheathing covers 40% or less of the exterior, continuous insulation R-value may be reduced by no more than R-3 in the locations where structural sheathing is used – to maintain a consistent total sheathing thickness. h. The second R-value applies when more than half the insulation is on the interior of the mass wall.

Part III - Mandatory Provisions

The following requirements (see code for full text) apply to all new single-family residential buildings.

Indicate that you understand and will comply with the following provisions by checking each box.

Table N1102.4.1.1 (R402.4.1.1) Air Barrier and Insulation Installation Air Leakage Requirements

The components of the building thermal envelope as listed in Table N1102.4.1.1 shall be installed in accordance with manufacturer's installation instructions and the following criteria:

MRC Sec. #	Description	<input checked="" type="checkbox"/>
N1101.12.1 and 1.1	<p>Insulation Products. For insulation products that do not have an identification mark from the manufacturer, the insulation installer shall provide a certification listing the type, manufacturer and R-value of insulation in each element of the building thermal envelope.</p> <p>For blown or sprayed insulation, the initial thickness, settled thickness, settled R-value, installed density, coverage area and number of bags shall be listed on the certification. In addition, markers shall be installed throughout attic spaces in accordance with N1101.12.1.1.</p> <p>For sprayed polyurethane foam insulation, the installed thickness of the areas covered and the R-value of the installed thickness shall be listed on the certification. Insulation certificates shall be submitted and approved by the Building Department prior to issuance of a Certificate of Occupancy.</p>	<input type="checkbox"/>

N1101.16	Energy Code Certificate. Prior to final inspection, a permanent energy code certificate shall be posted on or in the electrical distribution panel. Such certificate shall be on a label approved by the Building Department and include all information required by Section N1101.16.	<input type="checkbox"/>																																																			
N1102.4.1.2, N1105, or N1106	Air Leakage Testing - The building or dwelling unit shall be tested and verified as having an air leakage rate not exceeding the limits of the compliance path chosen. Testing shall be conducted by a certified independent third party. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope and such testing shall be conducted in the manner outlined in Section N1102.4.1.2. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official.	<input type="checkbox"/>																																																			
N1102.4.1.1	<p>Air Leakage – The components of the building thermal envelope as listed in Table N1102.4.1.1 shall be installed in accordance with manufacturer’s installation instructions and the following criteria: TABLE N1102.4.1.1 (R402.4.1.1) AIR BARRIER AND INSULATION INSTALLATION</p> <table border="1" data-bbox="305 478 1377 1814"> <thead> <tr> <th data-bbox="305 478 537 520">COMPONENT</th> <th data-bbox="537 478 1305 520">CRITERIA ^a</th> <th data-bbox="1305 478 1377 520"><input checked="" type="checkbox"/></th> </tr> </thead> <tbody> <tr> <td data-bbox="305 520 537 653">Air barrier and thermal barrier</td> <td data-bbox="537 520 1305 653">A continuous air barrier shall be installed in the building envelope. Exterior thermal envelope contains a continuous air barrier. Breaks or joints in the air barrier shall be sealed. Air-permeable insulation shall not be used as a sealing material.</td> <td data-bbox="1305 520 1377 653"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 653 537 751">Ceiling/attic</td> <td data-bbox="537 653 1305 751">The air barrier in any dropped ceiling/soffit shall be aligned with the insulation and any gaps in the air barrier sealed. Access openings, drop down stair, or knee wall doors to unconditioned attic spaces shall be sealed.</td> <td data-bbox="1305 653 1377 751"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 751 537 953">Walls</td> <td data-bbox="537 751 1305 953">Corners and headers shall be insulated and the junction of the foundation and sill plate shall be sealed. The junction of the top plate and top of exterior walls shall be sealed. Exterior thermal envelope insulation for framed walls shall be installed in substantial contact and continuous alignment with the air barrier. Knee walls shall be sealed.</td> <td data-bbox="1305 751 1377 953"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 953 537 1016">Windows, skylights and doors</td> <td data-bbox="537 953 1305 1016">The space between window/door jambs and framing, and skylights and framing shall be sealed.</td> <td data-bbox="1305 953 1377 1016"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1016 537 1052">Rim joists</td> <td data-bbox="537 1016 1305 1052">Rim joists shall be insulated and include the air barrier.</td> <td data-bbox="1305 1016 1377 1052"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1052 537 1150">Floors (including above-garage and cantilevered floors)</td> <td data-bbox="537 1052 1305 1150">Insulation shall be installed to maintain permanent contact with underside of subfloor decking. The air barrier shall be installed at any exposed edge of insulation.</td> <td data-bbox="1305 1052 1377 1150"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1150 537 1249">Crawl space walls</td> <td data-bbox="537 1150 1305 1249">Where provided in lieu of floor insulation, insulation shall be permanently attached to the crawlspace walls. Exposed earth in unvented crawl spaces shall be covered with a Class I vapor retarder with overlapping joints taped.</td> <td data-bbox="1305 1150 1377 1249"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1249 537 1312">Shafts, penetrations</td> <td data-bbox="537 1249 1305 1312">Duct shafts, utility penetrations, and flue shafts opening to exterior or unconditioned space shall be sealed.</td> <td data-bbox="1305 1249 1377 1312"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1312 537 1375">Narrow cavities</td> <td data-bbox="537 1312 1305 1375">Batts in narrow cavities shall be cut to fit, or narrow cavities shall be filled by insulation that on installation readily conforms to the available cavity space.</td> <td data-bbox="1305 1312 1377 1375"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1375 537 1411">Garage separation</td> <td data-bbox="537 1375 1305 1411">Air sealing shall be provided between the garage and conditioned spaces.</td> <td data-bbox="1305 1375 1377 1411"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1411 537 1474">Recessed lighting</td> <td data-bbox="537 1411 1305 1474">Recessed light fixtures installed in the building thermal envelope shall be air tight, IC rated, and sealed to the drywall.</td> <td data-bbox="1305 1411 1377 1474"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1474 537 1593">Plumbing and wiring</td> <td data-bbox="537 1474 1305 1593">Batt insulation shall be cut neatly to fit around wiring and plumbing in exterior walls, or insulation that on installation readily conforms to available space shall extend behind piping and wiring.</td> <td data-bbox="1305 1474 1377 1593"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1593 537 1656">Shower/tub on exterior wall</td> <td data-bbox="537 1593 1305 1656">Exterior walls adjacent to showers and tubs shall be insulated and the air barrier installed separating them from the showers and tubs.</td> <td data-bbox="1305 1593 1377 1656"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1656 537 1719">Electrical/phone box on exterior walls</td> <td data-bbox="537 1656 1305 1719">The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.</td> <td data-bbox="1305 1656 1377 1719"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1719 537 1782">HVAC register boots</td> <td data-bbox="537 1719 1305 1782">HVAC register boots penetrating building thermal envelope shall be sealed to the subfloor or drywall.</td> <td data-bbox="1305 1719 1377 1782"><input type="checkbox"/></td> </tr> <tr> <td data-bbox="305 1782 537 1814">Fireplace</td> <td data-bbox="537 1782 1305 1814">An air barrier shall be installed on fireplace walls. *</td> <td data-bbox="1305 1782 1377 1814"><input type="checkbox"/></td> </tr> </tbody> </table> <p data-bbox="305 1814 1094 1843">^a. In addition, inspection of log walls shall be in accordance with the provisions of ICC-400.</p>	COMPONENT	CRITERIA ^a	<input checked="" type="checkbox"/>	Air barrier and thermal barrier	A continuous air barrier shall be installed in the building envelope. Exterior thermal envelope contains a continuous air barrier. Breaks or joints in the air barrier shall be sealed. Air-permeable insulation shall not be used as a sealing material.	<input type="checkbox"/>	Ceiling/attic	The air barrier in any dropped ceiling/soffit shall be aligned with the insulation and any gaps in the air barrier sealed. Access openings, drop down stair, or knee wall doors to unconditioned attic spaces shall be sealed.	<input type="checkbox"/>	Walls	Corners and headers shall be insulated and the junction of the foundation and sill plate shall be sealed. The junction of the top plate and top of exterior walls shall be sealed. Exterior thermal envelope insulation for framed walls shall be installed in substantial contact and continuous alignment with the air barrier. Knee walls shall be sealed.	<input type="checkbox"/>	Windows, skylights and doors	The space between window/door jambs and framing, and skylights and framing shall be sealed.	<input type="checkbox"/>	Rim joists	Rim joists shall be insulated and include the air barrier.	<input type="checkbox"/>	Floors (including above-garage and cantilevered floors)	Insulation shall be installed to maintain permanent contact with underside of subfloor decking. The air barrier shall be installed at any exposed edge of insulation.	<input type="checkbox"/>	Crawl space walls	Where provided in lieu of floor insulation, insulation shall be permanently attached to the crawlspace walls. Exposed earth in unvented crawl spaces shall be covered with a Class I vapor retarder with overlapping joints taped.	<input type="checkbox"/>	Shafts, penetrations	Duct shafts, utility penetrations, and flue shafts opening to exterior or unconditioned space shall be sealed.	<input type="checkbox"/>	Narrow cavities	Batts in narrow cavities shall be cut to fit, or narrow cavities shall be filled by insulation that on installation readily conforms to the available cavity space.	<input type="checkbox"/>	Garage separation	Air sealing shall be provided between the garage and conditioned spaces.	<input type="checkbox"/>	Recessed lighting	Recessed light fixtures installed in the building thermal envelope shall be air tight, IC rated, and sealed to the drywall.	<input type="checkbox"/>	Plumbing and wiring	Batt insulation shall be cut neatly to fit around wiring and plumbing in exterior walls, or insulation that on installation readily conforms to available space shall extend behind piping and wiring.	<input type="checkbox"/>	Shower/tub on exterior wall	Exterior walls adjacent to showers and tubs shall be insulated and the air barrier installed separating them from the showers and tubs.	<input type="checkbox"/>	Electrical/phone box on exterior walls	The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.	<input type="checkbox"/>	HVAC register boots	HVAC register boots penetrating building thermal envelope shall be sealed to the subfloor or drywall.	<input type="checkbox"/>	Fireplace	An air barrier shall be installed on fireplace walls. *	<input type="checkbox"/>	
COMPONENT	CRITERIA ^a	<input checked="" type="checkbox"/>																																																			
Air barrier and thermal barrier	A continuous air barrier shall be installed in the building envelope. Exterior thermal envelope contains a continuous air barrier. Breaks or joints in the air barrier shall be sealed. Air-permeable insulation shall not be used as a sealing material.	<input type="checkbox"/>																																																			
Ceiling/attic	The air barrier in any dropped ceiling/soffit shall be aligned with the insulation and any gaps in the air barrier sealed. Access openings, drop down stair, or knee wall doors to unconditioned attic spaces shall be sealed.	<input type="checkbox"/>																																																			
Walls	Corners and headers shall be insulated and the junction of the foundation and sill plate shall be sealed. The junction of the top plate and top of exterior walls shall be sealed. Exterior thermal envelope insulation for framed walls shall be installed in substantial contact and continuous alignment with the air barrier. Knee walls shall be sealed.	<input type="checkbox"/>																																																			
Windows, skylights and doors	The space between window/door jambs and framing, and skylights and framing shall be sealed.	<input type="checkbox"/>																																																			
Rim joists	Rim joists shall be insulated and include the air barrier.	<input type="checkbox"/>																																																			
Floors (including above-garage and cantilevered floors)	Insulation shall be installed to maintain permanent contact with underside of subfloor decking. The air barrier shall be installed at any exposed edge of insulation.	<input type="checkbox"/>																																																			
Crawl space walls	Where provided in lieu of floor insulation, insulation shall be permanently attached to the crawlspace walls. Exposed earth in unvented crawl spaces shall be covered with a Class I vapor retarder with overlapping joints taped.	<input type="checkbox"/>																																																			
Shafts, penetrations	Duct shafts, utility penetrations, and flue shafts opening to exterior or unconditioned space shall be sealed.	<input type="checkbox"/>																																																			
Narrow cavities	Batts in narrow cavities shall be cut to fit, or narrow cavities shall be filled by insulation that on installation readily conforms to the available cavity space.	<input type="checkbox"/>																																																			
Garage separation	Air sealing shall be provided between the garage and conditioned spaces.	<input type="checkbox"/>																																																			
Recessed lighting	Recessed light fixtures installed in the building thermal envelope shall be air tight, IC rated, and sealed to the drywall.	<input type="checkbox"/>																																																			
Plumbing and wiring	Batt insulation shall be cut neatly to fit around wiring and plumbing in exterior walls, or insulation that on installation readily conforms to available space shall extend behind piping and wiring.	<input type="checkbox"/>																																																			
Shower/tub on exterior wall	Exterior walls adjacent to showers and tubs shall be insulated and the air barrier installed separating them from the showers and tubs.	<input type="checkbox"/>																																																			
Electrical/phone box on exterior walls	The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.	<input type="checkbox"/>																																																			
HVAC register boots	HVAC register boots penetrating building thermal envelope shall be sealed to the subfloor or drywall.	<input type="checkbox"/>																																																			
Fireplace	An air barrier shall be installed on fireplace walls. *	<input type="checkbox"/>																																																			
N1102.4.2	Fireplaces – Wood-burning masonry fireplaces shall have tight-fitting flue dampers & outdoor combustion air.	<input type="checkbox"/>																																																			
N1102.4.3	Fenestration Air Leakage – Windows, skylights and sliding glass doors shall have an air infiltration rate of no more than 0.3 cfm per square foot, and swinging doors on more than 0.5 cfm per square foot, when tested according to NFRC 400 or AAMA/WDMA/CSA 101/I.S.2/A440 by an accredited, independent laboratory and listed and labeled by the manufacturer. Exceptions: Site built windows, skylights and doors. Labels shall	<input type="checkbox"/>																																																			

	remain on windows until after insulation inspection.	
N1102.4.4	Recessed Lighting – Recessed luminaires installed in the building thermal envelope shall be sealed to limit air leakage between conditioned and unconditioned spaces. All recessed luminaires shall be IC-rated and labeled as having an air leakage rate not more than 2.0 cfm when tested in accordance with ASTM E283 at a 1.57 psf pressure differential. All recessed luminaires shall be sealed with a gasket or caulk between the housing and the interior wall or ceiling covering.	<input type="checkbox"/>
N1103.1	Controls – Provide at least one thermostat for each separate heating and cooling system	<input type="checkbox"/>
N1103.1.1	Programmable thermostat. Where the primary heating system is a forced-air furnace, at least one thermostat per dwelling unit shall be capable of controlling the heating and cooling system on a daily schedule to maintain different temperature set points at different times of the day. This thermostat shall include the capability to set back or temporarily operate the system to maintain zone temperatures down to 55°F or up to 85°F. The thermostat shall initially be programmed with a heating temperature set point no higher than 70°F and a cooling temperature set point no lower than 78°F.	<input type="checkbox"/>
N1103.1.2	Heat pump supplementary heat - Heat pumps having supplementary electric resistance heat shall have controls that, except during defrost, prevent supplemental heat operation when the heat pump compressor can meet the heating load.	<input type="checkbox"/>
N1103.2.2	Sealing - Ducts, air handlers, and filter boxes shall be sealed with approved sealants, including joints and seams. With the following Exceptions : <ol style="list-style-type: none"> 1. Air-impermeable spray foam products may be applied without additional joint seals. 2. Where a duct connection is made that is partially inaccessible, 3 screws or rivets shall be equally spaced on the exposed portion of the joint so as to prevent a hinge effect. 3. Continuously welded and locking-type longitudinal joints and seams, other than snap- lock and button-type per Sec. M1601.4.1, in ducts operating at static pressures < 2 inches of water column pressure classification shall not require additional closure systems. 	<input type="checkbox"/>
N1103.2.2	Ducts and air handlers located outside the building thermal envelope or located within the building envelope assembly – Duct tightness shall be verified by either a Rough-in or Post Construction pressure test in accordance with Section N1103.2.2. A written report of the test results, signed by the party conducting the test, shall be provided to the code official prior to the issuance of a certificate of occupancy.	<input type="checkbox"/>
N1103.2.3	Building Cavities – Building framing cavities shall not be used as supply ducts or plenums.	<input type="checkbox"/>
N1103.3	Mechanical system piping insulation - Mechanical system piping capable of carrying fluids above 105°F or below 55°F shall be insulated to a minimum of R-3.	<input type="checkbox"/>
N1103.3.1	Protection of piping insulation. Piping insulation exposed to weather shall be protected from damage, including that caused by sunlight, moisture, equipment maintenance, and wind, and shall provide shielding from solar radiation that can cause degradation of the material. Adhesive tape shall not be permitted as a protection method.	<input type="checkbox"/>
N1103.4.1	Circulating hot water systems - Circulating hot water systems must have an automatic or readily accessible manual switch to turn off the hot-water circulating pump when not in use.	<input type="checkbox"/>
N1103.5	Mechanical ventilation - The building shall be provided with ventilation meeting requirements of Section M1507 or with other approved means of ventilation. Outdoor air intakes and exhausts shall have automatic or gravity dampers that close when the ventilation system is not operating.	<input type="checkbox"/>
N1103.6	Heating and Cooling Equipment Sizing – Heating and cooling equipment shall be sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other approved heating and cooling calculation methodologies. A heating/cooling plan, Manual J calculations, equipment sizes and efficiencies, duct R values, and supporting documentation shall be submitted to the Inspector at the rough mechanical inspection. All information shall be kept with the furnace and available for Final Inspection.	<input type="checkbox"/>
N1103.8	Snow melt system controls - Snow and ice-melting systems, supplied through energy service to the building, shall include automatic controls capable of shutting off the system when the pavement temperature is above 50°F, and no precipitation is falling and an automatic or manual control that will allow shutoff when the outdoor temperature is above 40°F.	<input type="checkbox"/>
N1103.9	Pools and in-ground permanently installed spas - Pools and in-ground permanently installed spas shall comply with Sections N1103.9.1 through N1103.9.3.	<input type="checkbox"/>
N1104.1	Lighting equipment - A minimum of 75 percent of the lamps in permanently installed lighting fixtures shall be high-efficiency lamps or a minimum of 75 percent of the permanently installed lighting fixtures shall contain only high-efficiency lamps. Exception: Low-voltage lighting	
N1104.1.1	Gas Lighting equipment - Fuel gas systems shall not have continuously burning pilot lights.	